

CERTIFICATE OF ACCREDITATION

This is to certify that:

ATLAS FIRE SECURITY (PTY) LTD

Co. reg. no: 72/06703/07

Facility Accreditation Number: **IGS0013**

is a South African National Accreditation System accredited Inspection Body to undertake **Type C** Inspection provided that all SANAS conditions and requirements are complied with

This certificate is valid as per the scope on the accompanying schedule of accreditation bearing the above accreditation number for

INSPECTION OF TRANSPORTABLE REFILLABLE GAS CONTAINERS

The inspection body complies with the general requirements of

ISO/IEC 17020:1998

While this certificate remains valid, the Accredited Facility named above is authorised to use the relevant SANAS accreditation symbol to issue facility reports and/or certificates

Mr MA Peet
Chief Executive Officer

Initial Accreditation: 27 January 2004

Certificate Commences: 01 October 2008

Certificate Expires: 27 January 2012

"Recognised as the official national accreditation body by the Department of Trade and Industry of the Republic of South Africa"

This certificate is only valid when accompanied by its schedule of accreditation.

SCHEDULE OF ACCREDITATION

Inspection Body Accreditation Number: IGS0013

TYPE C

<p><u>Permanent Address of Inspection Body:</u> Atlas Fire Security (Pty) Ltd 39 Stella Road Montague Gardens Cape Town 7442</p> <p>Tel : (021) 551-5080 Fax : (021) 552-5773 E-mail : atlsfire@mweb.co.za</p>	<p><u>Postal Address:</u> P O Box 36634 Chempet 7442</p> <p>Issue No. : 06 Date of issue : 01 October 2008 Expiry date : 27 January 2012</p>	<p><u>Unique Company Stamp:</u></p> <p style="text-align: center; font-size: 2em; font-weight: bold;">A T H</p>
<p><u>Management Representative:</u> Ms L Davel</p>	<p><u>Quality Manager:</u> Ms L Davel</p> <p><u>Technical Manager:</u> Mr JHG Davel</p>	<p><u>Signatories:</u> Mr M Thomas Mr H Davel Mr M Mtsila</p>
Field of Inspection	Service Rendered	Codes and Regulations
<p><u>Regulatory:</u> The supply of services as a Test Station as defined in the Vessels Under Pressure Regulation, Government notice No. R1591 of 4 October 1996</p>	<p><u>Specific Services:</u> The statutory inspection and test of seamless steal and aluminium CO2 cylinders used for fire fighting applications</p> <p><u>Cylinder Capacity:</u> Water capacity 0.5 Litre to 1200 Litres</p>	<p><u>Principal codes:</u> SANS 10019 SANS 1825 SANS/ISO 6406 BS 5045-8</p>

Original date of accreditation: 27 January 2004

Page 1 of 1

ISSUED BY THE SOUTH AFRICAN NATIONAL ACCREDITATION SYSTEM

Field Manager